

1 [Electrical Code - Low Voltage Lighting; Correction of Section Title]

2  
3 **Ordinance amending the Electrical Code to correct the title for the Low Voltage**  
4 **Lighting section and conform it to the title in the California Electrical Code.**

5 NOTE: **Unchanged Code text and uncodified text** are in plain Arial font.  
6 **Additions to Codes** are in *single-underline italics Times New Roman font*.  
7 **Deletions to Codes** are in *strikethrough italics Times New Roman font*.  
8 **Board amendment additions** are in double-underlined Arial font.  
9 **Board amendment deletions** are in ~~strikethrough Arial font~~.  
10 **Asterisks (\* \* \* \*)** indicate the omission of unchanged Code  
11 subsections or parts of tables.

12 Be it ordained by the People of the City and County of San Francisco:

13 Section 1. Findings.

14 (a) On August 16, 2017, the Building Inspection Commission considered this  
15 ordinance at a duly noticed public hearing pursuant to Charter Section D3.750-5.

16 (b) No finding is required under California Health and Safety Code Section 17958.7  
17 because the ordinance does not amend a “building standard” as defined in Section 18909 of  
18 the Health and Safety Code. The proposed amendment to Section 411.5 corrects the title of  
19 the section in the San Francisco Electrical Code and conforms it to the California Electrical  
20 Code.

21 Section 2. The Electrical Code is hereby amended by revising Section 411.5, to read  
22 as follows:

23 411.5 *Specific Locations Requirements* ~~Requirements~~ *not Permitted*.

24 (A) **Walls, Floors and Ceilings.** Conductors concealed or extended through a wall, floor,  
25 ceiling, or suspended ceiling, shall be in accordance with (1) or (2):

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

(1) Installed using any of the wiring methods specified in Chapter 3.

(2) Installed using wiring supplied by a listed Class 2 power source and installed in accordance with 725.130.

\* \* \* \*

Section 3. Effective Date. This ordinance shall become effective 30 days after enactment. Enactment occurs when the Mayor signs the ordinance, the Mayor returns the ordinance unsigned or does not sign the ordinance within ten days of receiving it, or the Board of Supervisors overrides the Mayor's veto of the ordinance.

Section 4. Scope of Ordinance. In enacting this ordinance, the Board of Supervisors intends to amend only those words, phrases, paragraphs, subsections, sections, articles, numbers, punctuation marks, charts, diagrams, or any other constituent parts of the Municipal Code that are explicitly shown in this ordinance as additions, deletions, Board amendment additions, and Board amendment deletions in accordance with the "Note" that appears under the official title of the ordinance.

APPROVED AS TO FORM:  
DENNIS J. HERRERA, City Attorney

By:   
JUDITH A. BOYAJIAN  
Deputy City Attorney

n:\legana\as2017\1700717\01210517.docx



# City and County of San Francisco

## Tails

## Ordinance

City Hall  
1 Dr. Carlton B. Goodlett Place  
San Francisco, CA 94102-4689

**File Number:** 170971

**Date Passed:** April 24, 2018

Ordinance amending the Electrical Code to correct the title for the Low Voltage Lighting section and conform it to the title in the California Electrical Code.

April 09, 2018 Land Use and Transportation Committee - RECOMMENDED

April 17, 2018 Board of Supervisors - PASSED ON FIRST READING


Ayes: 11 - Breed, Cohen, Fewer, Kim, Peskin, Ronen, Safai, Sheehy, Stefani, Tang and Yee

April 24, 2018 Board of Supervisors - FINALLY PASSED

Ayes: 11 - Breed, Cohen, Fewer, Kim, Peskin, Ronen, Safai, Sheehy, Stefani, Tang and Yee

File No. 170971

I hereby certify that the foregoing  
Ordinance was FINALLY PASSED on  
4/24/2018 by the Board of Supervisors of  
the City and County of San Francisco.

  
\_\_\_\_\_  
Angela Calvillo  
Clerk of the Board

  
\_\_\_\_\_  
Mark E. Farrell  
Mayor

  
\_\_\_\_\_  
Date Approved