

File No. 190963 Committee Item No. 5
 Board Item No. 5

COMMITTEE/BOARD OF SUPERVISORS
 AGENDA PACKET CONTENTS LIST

Committee: Land Use and Transportation Committee Date October 28, 2019

Board of Supervisors Meeting
 Cmte Board

Date NOVEMBER 12, 2019

- | | | |
|-------------------------------------|-------------------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | Motion |
| <input type="checkbox"/> | <input type="checkbox"/> | Resolution |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | Ordinance |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | Legislative Digest |
| <input type="checkbox"/> | <input type="checkbox"/> | Budget and Legislative Analyst Report |
| <input type="checkbox"/> | <input type="checkbox"/> | Youth Commission Report |
| <input type="checkbox"/> | <input type="checkbox"/> | Introduction Form |
| <input type="checkbox"/> | <input type="checkbox"/> | Department/Agency Cover Letter and/or Report |
| <input type="checkbox"/> | <input type="checkbox"/> | MOU |
| <input type="checkbox"/> | <input type="checkbox"/> | Grant Information Form |
| <input type="checkbox"/> | <input type="checkbox"/> | Grant Budget |
| <input type="checkbox"/> | <input type="checkbox"/> | Subcontract Budget |
| <input type="checkbox"/> | <input type="checkbox"/> | Contract/Agreement |
| <input type="checkbox"/> | <input type="checkbox"/> | Form 126 – Ethics Commission |
| <input type="checkbox"/> | <input type="checkbox"/> | Award Letter |
| <input type="checkbox"/> | <input type="checkbox"/> | Application |
| <input type="checkbox"/> | <input type="checkbox"/> | Public Correspondence |

OTHER (Use back side if additional space is needed)

- | | | |
|-------------------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>DRAFT 2019 SFPC</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>Exhibit A Findings</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>2019 CPC <-- *** CLICK HERE TO VIEW</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>BIC Ltr 081219</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>DBI Ltr 092019</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>Referral CEQA 100819</u> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <u>CEQA Determination 101519</u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u> </u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u> </u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u> </u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u> </u> |

Completed by: Erica Major Date October 24, 2019
 Completed by: Erica Major Date 10/31/2019

1 [Plumbing Code - Repeal of Existing 2016 Code and Enactment of 2019 Edition]

2
3 Ordinance repealing the 2016 Plumbing Code in its entirety and enacting a 2019
4 Plumbing Code consisting of the 2019 California Plumbing Code as amended by San
5 Francisco; adopting environmental findings and findings of local conditions under the
6 California Health and Safety Code; providing an operative date of January 1, 2020; and
7 directing the Clerk of the Board of Supervisors to forward the legislation to the
8 California Building Standards Commission as required by State law.

9 NOTE: Unchanged Code text and uncodified text are in plain Arial font.
10 Additions to Codes are in single-underline italics Times New Roman font.
11 Deletions to Codes are in ~~strikethrough italics Times New Roman font~~.
12 Board amendment additions are in double-underlined Arial font.
13 Board amendment deletions are in ~~strikethrough-Arial font~~.
14 Asterisks (* * * *) indicate the omission of unchanged Code
15 subsections or parts of tables.

14 Be it ordained by the People of the City and County of San Francisco:

15 Section 1. Environmental Findings. The Planning Department has determined that the
16 actions contemplated in this ordinance comply with the California Environmental Quality Act
17 (California Public Resources Code Sections 21000 et seq.). Said determination is on file with
18 the Clerk of the Board of Supervisors in File No. 190963 and is incorporated herein by
19 reference. The Board affirms this determination.

20
21 Section 2. General Findings.

22 (a) The California Building Standards Code is contained in Title 24 of the California
23 Code of Regulations. It consists of 12 Parts, which are based upon model codes that are
24 amended by the State agencies with jurisdiction over the subject matter. The California
25 Plumbing Code is Part 5 of Title 24 of the California Code of Regulations.

1 (b) The State of California adopts a new California Building Standards Code every
2 three years ("triennial CBSC") with supplemental amendments published in intervening years.
3 The triennial CBSC goes into effect throughout the State of California 180 days after its
4 publication by the California Building Standards Commission or at a later date established by
5 the Commission. The 2019 triennial CBSC will go into effect on January 1, 2020.

6 (c) Local jurisdictions must enforce the California Building Standards Code but they
7 may also enact more restrictive building standards that are reasonably necessary because of
8 local climate, geologic, or topographical conditions. Local amendments may be made both to
9 the triennial CBSC and to its individual Parts during the intervening years; however, local
10 amendments previously adopted are not automatically applicable to a triennial CBSC. Rather,
11 they must be re-enacted with the required findings of local climate, geologic, or topographical
12 conditions, expressly made applicable to the new triennial CBSC, and with an operative date
13 no earlier than the effective date of the triennial CBSC.

14 (d) As in past triennial CBSC adoption cycles, by this ordinance the Board of
15 Supervisors repeals the 2016 San Francisco Plumbing Code in its entirety, enacts the 2019
16 San Francisco Plumbing Code, and re-enacts the existing local amendments to make them
17 applicable to the 2019 California Plumbing Code.

18 (e) Pursuant to Charter Section D3.750-5, the Building Inspection Commission
19 considered and approved San Francisco's amendments to the 2019 California Plumbing Code
20 at a duly noticed public hearing that was held on July 17, 2019.

21
22 Section 3. Findings regarding Local Conditions.

23 (a) California Health and Safety Code Sections 17958.7 and 18941.5 provide that
24 before making any changes or modifications to the California Plumbing Code and any other
25 applicable provisions published by the California Building Standards Commission, the

1 governing body must make an express finding that each such change or modification is
2 reasonably necessary because of specified local conditions. The local amendments together
3 with the required findings must be filed with the California Building Standards Commission
4 before the local changes or modifications can go into effect.

5 (b) The City and County of San Francisco is unique among California communities
6 with respect to local climate, geologic, topographical, and other conditions. A specific list of
7 findings that support San Francisco's modifications to the 2019 California Plumbing Code,
8 with a section-by-section correlation of each modification with a specific numbered finding, are
9 contained in Exhibit A entitled "Standard Findings for San Francisco Building Standards Code
10 Amendments."

11 (c) Pursuant to California Health and Safety Code Sections 17958.7 and 18941.5,
12 the Board of Supervisors finds and determines that the local conditions described in Exhibit A
13 constitute a general summary of the most significant local conditions giving rise to the need
14 for modification of the 2019 California Plumbing Code provisions published by the California
15 Building Standards Commission. The Board of Supervisors further finds and determines that
16 the proposed modifications are reasonably necessary based upon the local conditions set
17 forth in Exhibit A.

18
19 Section 4. Repeal of the 2016 San Francisco Plumbing Code and Enactment of the
20 2019 San Francisco Plumbing Code.

21 (a) The 2016 San Francisco Plumbing Code is hereby repealed in its entirety. The
22 San Francisco Plumbing Code being repealed was enacted on November 22, 2016, by
23 Ordinance No. 231-16, with an operative date of January 1, 2017. It was amended by
24 Ordinance Nos. 0096-18, 0065-19, and 0087-19. These ordinances are available on the
25 Board of Supervisors' website.

1 (b) The 2019 San Francisco Plumbing Code is hereby enacted. It consists of the
2 2019 California Plumbing Code and San Francisco's existing local amendments, which are re-
3 enacted and expressly made applicable to the 2019 California Plumbing Code. Copies of the
4 2019 California Plumbing Code and the stand-alone San Francisco amendments are declared
5 to be part of Board File No. 190963 and are incorporated into this ordinance by reference as
6 though fully set forth. Existing San Francisco amendments that are being made applicable to
7 the 2019 California Plumbing Code are shown in unformatted ("plain") text and may include
8 bold and/or italicized formatting; new San Francisco amendments are underlined; and deleted
9 San Francisco amendments are in strikeout text.

10
11 Section 5. Continuation of Actions Under Prior Code. Nothing contained in this
12 ordinance shall be construed as abating any action now pending under or by virtue of any
13 ordinance of the City and County of San Francisco hereby repealed, nor shall this ordinance
14 be construed as discontinuing, abating, modifying or altering any penalties accruing, or to
15 accrue, or as waiving any right of the City under any such ordinance.

16
17 Section 6. Severability. If any section, subsection, sentence, clause, or phrase of this
18 ordinance is, for any reason, held to be invalid, such decision shall not affect the validity of the
19 remaining portions of this ordinance. The Board of Supervisors hereby declares that it would
20 have passed this ordinance, and each section, subsection, sentence, clause, or phrase of this
21 ordinance, irrespective of the fact that any one or more sections, subsections, sentences,
22 clauses, or phrases be declared invalid.


23
24 Section 7. Effective and Operative Dates. This ordinance shall become effective 30
25 days after enactment. Enactment occurs when the Mayor signs the ordinance, the Mayor

1 returns the ordinance unsigned or does not sign the ordinance within ten days of receiving it,
2 or the Board of Supervisors overrides the Mayor's veto of the ordinance. This ordinance shall
3 take effect and be in full force on and after either January 1, 2020 or its effective date if the
4 effective date is later.

5
6 Section 8. Directions to Clerk. Upon final passage of this ordinance, the Clerk of the
7 Board of Supervisors is hereby directed to transmit to to the California Building Standards
8 Commission pursuant to the applicable provisions of State law 1) this ordinance, 2) the Exhibit
9 A attachment, and 3) the San Francisco amendments to the 2019 California Plumbing Code.

10
11 APPROVED AS TO FORM:
12 DENNIS J. HERRERA, City Attorney

13 By:


14 JUDITH A. BOYAJIAN
Deputy City Attorney

15 n:\egana\as2019\1900415\01391085.docx
16
17
18
19
20
21
22
23
24
25

LEGISLATIVE DIGEST

[Plumbing Code - Repeal of Existing 2016 Code and Enactment of 2019 Edition]

Ordinance repealing the 2016 Plumbing Code in its entirety and enacting a 2019 Plumbing Code consisting of the 2019 California Plumbing Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing an operative date of January 1, 2020; and directing the Clerk of the Board of Supervisors to forward the legislation to the California Building Standards Commission as required by State law.

Existing Law

The Plumbing Code regulates the installation and maintenance of plumbing systems and fixtures, water heaters, water supply and distribution, sanitation and ventilation systems, drainage, fuel piping, and medical and gas vacuum systems. The current San Francisco Plumbing Code consists of the 2016 California Plumbing Code (which incorporates the 2015 Uniform Plumbing Code) and San Francisco's local amendments to the 2019 California Plumbing Code ("San Francisco Amendments").

Amendments to Current Law


Every three years the State of California adopts a new California Building Standards Code ("triennial CBSC"), which amends the California Plumbing Code and the other state codes that constitute the CBSC. The 2019 triennial CBSC will go into effect throughout the State on January 1, 2020. As in past triennial CBSC adoption cycles, San Francisco will repeal its existing Plumbing Code in its entirety and adopt a new Plumbing Code that applies San Francisco's existing local amendments to the new California Plumbing Code. Except for non-substantive or technical modifications required by amendments to the state code, there are no changes to the existing San Francisco Plumbing Code amendments being carried forward.

Background Information

Local jurisdictions are required to enforce the California Building Standards Code but they may also enact more restrictive building standards that are reasonably necessary because of local climate, geology, or topography. Local amendments may be made to a triennial CBSC and also throughout the intervening years. However, local amendments previously adopted are not automatically transferred to a new triennial CBSC. Rather, they must be re-enacted with the required findings of local climate, geologic, or topographical conditions, expressly made applicable to the new triennial CBSC, and with an operative date no earlier than the effective date of the new State Code.

n:\legana\as2019\1900415\01384329.doc

BOARD of SUPERVISORS



City Hall
Dr. Carlton B. Goodlett Place, Room 244
San Francisco 94102-4689
Tel. No. 554-5184
Fax No. 554-5163
TDD/TTY No. 554-5227

October 8, 2019

File No. 190959-190964

Lisa Gibson
Environmental Review Officer
Planning Department
1650 Mission Street, Ste. 400
San Francisco, CA 94103

Dear Ms. Gibson:

On October 1, 2019, the Building Inspection Commission submitted the proposed legislation:

File No. 190959

Ordinance repealing the 2016 Building Code in its entirety and enacting a 2019 Building Code consisting of the 2019 California Building Code and the 2019 California Residential Code, as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing for an operative date of January 1, 2020; and directing the Clerk of the Board to forward the legislation to the California Building Standards Commission as required by State law.

File No. 190960

Ordinance repealing the 2016 Existing Building Code in its entirety and enacting a 2019 Existing Building Code consisting of the 2019 California Existing Building Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing for an operative date of January 1, 2020; and directing the Clerk of the Board to forward the legislation to the California Building Standards Commission as required by State law.

File No. 190961

Ordinance repealing the 2016 Electrical Code in its entirety and enacting a 2019 Electrical Code consisting of the 2019 California Electrical Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing an operative date of January 1, 2020; and directing the Clerk of the Board of Supervisors to forward the legislation to the California Building Standards Commission as required by State law.

File No. 190962

Ordinance repealing the 2016 Mechanical Code in its entirety and enacting a 2019 Mechanical Code consisting of the 2019 California Mechanical Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing an operative date of January 1, 2020; and directing the Clerk of the Board of Supervisors to forward the legislation to the California Building Standards Commission as required by State law.

File No. 190963


Ordinance repealing the 2016 Plumbing Code in its entirety and enacting a 2019 Plumbing Code consisting of the 2019 California Plumbing Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing an operative date of January 1, 2020; and directing the Clerk of the Board of Supervisors to forward the legislation to the California Building Standards Commission as required by State law.

File No. 190964

Ordinance repealing the 2016 Green Building Code in its entirety and enacting a 2019 Green Building Code consisting of the 2019 California Green Building Standards Code as amended by San Francisco; adopting environmental findings and findings of local conditions under the California Health and Safety Code; providing for an operative date of January 1, 2020; and directing the Clerk of the Board of Supervisors to forward the legislation to the California Building Standards Commission as required by State law.

The above legislation are being transmitted to you for environmental review.

Angela Calvillo, Clerk of the Board



By: Erica Major, Assistant Clerk
Land Use and Transportation Committee

Attachment

- c: Joy Navarrete, Environmental Planning
Don Lewis, Environmental Planning
- Not defined as a project under CEQA Guidelines Sections 15378 and 15060(c)(2) because it would not result in a direct or indirect physical change in the environment.

Joy Navarrete 10/15/2019

2019

San Francisco Plumbing Code

**Amendments to the
2019 California Plumbing Code**

Operative date: January 1, 2020

PROPOSED SAN FRANCISCO PLUMBING CODE AMENDMENTS 2019 Edition

Text Format:

Unchanged language from the 2019 California Code is shaded, and may include **bold** and/or *italicized* formatting.

San Francisco amendments are printed in unformatted ("plain") text, and may include **bold** and/or *italicized* formatting.

Repealed San Francisco amendments appear ~~plain and strikeout~~.

New San Francisco amendments appear underlined.

Chapter 1

ADMINISTRATION

Division I

CALIFORNIA ADMINISTRATION

No San Francisco Plumbing Code Amendments

Division II

ADMINISTRATION

SECTION 101.0 – GENERAL

101.1 Revise this section as follows:

101.1 Title. This document shall be known as the "2016 2019 San Francisco Plumbing Code," may be cited as such, and will be referred to herein as "this code."

SECTION 103.0 – DUTIES AND POWERS OF THE AUTHORITY HAVING JURISDICTION

103.1 Replace the third paragraph with the followings:

The Authority Having Jurisdiction, when necessary, may call upon the Police Department and other City and County of San Francisco agencies for aid or assistance in carrying out or enforcing any of the provisions of this code.

103.4 Revise the first paragraph of this section as follows:

103.4 Right of Entry. Where it is necessary to make an inspection to enforce the provisions of this code or other codes or ordinances, or where the Authority Having Jurisdiction has reasonable cause to believe that

there exists in a building or upon premises a condition or violation of this code or other codes or ordinances that makes the building or premises unsafe, insanitary, dangerous or hazardous, the Authority Having Jurisdiction shall be permitted to enter the building or premises at reasonable times to inspect or to perform the duties imposed upon the Authority Having Jurisdiction by this code or other codes or ordinances, provided that where such building or premises is occupied, the Authority Having Jurisdiction shall present credentials to the occupant and request entry. Where such building or premises is unoccupied, the Authority Having Jurisdiction shall first make a reasonable effort to locate the owner or other person having charge or control of the building or premises and request entry. Where entry is refused, the Authority Having Jurisdiction has recourse to every remedy provided by law to secure entry.

103.5 Add the following section:

103.5 Rules and Regulations. The Authority Having Jurisdiction shall have the power to render interpretations of this code and to adopt and enforce rules and supplemental regulations to clarify the application of its provisions. Such interpretations, rules and regulations shall be in conformance with the intent and purpose of this code. Such rules and regulations, commonly referred to as "Code Rulings" and "Administrative Bulletins" supplemental to this code, shall not take effect until approved by the Building Inspection Commission and signed by the Authority Having Jurisdiction except in unusual circumstances where the Authority Having Jurisdiction has determined that there is an immediate need to protect the public health and safety. When the Authority Having Jurisdiction finds that such circumstances exist, the Authority Having Jurisdiction may order immediate enforcement of a particular rule or regulation. The Authority Having Jurisdiction shall arrange for a subscription service to such rules and regulations, the entire cost of which is to be borne by the subscribers.

103.6 Add the following section:

103.6 Code Revisions. The Authority Having Jurisdiction shall transmit to the Building Inspection Commission, at intervals not exceeding three years, recommendations for changes to this code, based on studies of the following:

1. Requests of the Board of Examiners for variances from this code, and for approvals of alternate materials, alternate designs and methods of construction.
2. Code changes recommended by the Board of Examiners.
3. Code changes recommended by the Code Advisory Committee or other bodies subordinate to the Building Inspection Commission.
4. Results obtained and problems encountered in legal actions taken to correct code violations.
5. Changes or improvements in materials, methods of construction or design, and changes proposed by interested persons.
6. Investigations of fire and structural damage to buildings, and of determination of unsatisfactory building performance.
7. Periodic changes to the California Plumbing Code and other State regulations which may affect this code.
8. Administrative Bulletins and Code Rulings currently in effect.
9. Violations of the code found on inspections or investigations.

103.7 Add the following section:

103.7 Modifications. When there are practical difficulties involved in carrying out the provisions of this code, the Authority Having Jurisdiction may grant modifications for individual cases. The Authority Having Jurisdiction shall first find that a special individual reason makes the strict letter of this code impractical and that the modification is in conformance with the intent and purpose of this code and that such modification does not lessen the standard of this code to safeguard life or limb, health, property, or public welfare. The details of any action granting modifications shall be recorded and entered in the files of the Department of

Building Inspection.

SECTION 104.0 – PERMITS

104.1 Add the following as the second paragraph of this section:

Emergency work for the protection of life or limb, health, property and public welfare shall have a permit obtained within one day of commencing such work, excluding Saturdays, Sundays and legal holidays.

104.1.1 Add the following section:

104.1.1 Homeowner's Permit. A permit for plumbing work in, on or about a single-family dwelling may be issued by the Authority Having Jurisdiction, provided said work is done by the owner or a family member who has demonstrated, to the satisfaction of the administrative authority, his or her qualifications to satisfactorily perform the plumbing work in the dwelling which is, or is intended to be, occupied by the owner. If the plumbing work performed under the homeowner's permit does not comply with the requirements of this code and if the corrections are not made as required by the Department of Building Inspection, then the work shall be corrected by a State-licensed plumbing contractor under a separate permit.

Such State-licensed plumbing contractor shall be required to pay only the permit issuance fee as set forth in Section 110A, Table 1A-C - Plumbing/Mechanical Permit Issuance and Inspection Fees - of the Building Code. If additional inspection is required, the appropriate fees as set forth in Section 110A, Table 1A-C - Plumbing/ Mechanical Permit Issuance and Inspection Fees and Table 1A-G - Inspection, Surveys and Reports - of the Building Code shall apply.

104.1.2 Add the following section:

104.1.2 Amending Applications. After a permit has been issued and an inspection of the work has been made, the scope of the permit may be altered by filing an amended permit application and paying fees for any additional work as set forth in Table 1A-C - Plumbing/ Mechanical Permit Issuance and Inspection Fees and Table 1A-G - Inspections, Survey, and Reports of Section 110A of the Building Code.

104.2 Replace Section 104.2(1) and the first paragraph of Section 104.2(2) as follows:

104.2 Exempt Work. A permit shall not be required for the following:

- (1) Repair of leaks not requiring cutting into or removing piping.
- (2) Unstopping of traps, sewers, vents or waste pipes not requiring cutting into or removal of traps or piping.
- (3) Replacement, repair or maintenance of faucets, angle stops, hose bibbs or roof drain not requiring cutting into or removal of piping.
- (4) Replacement of toilets except in structures with alternate water piping.
- (5) Replacement of furnace filters.
- (6) Removal of drainage, water or gas piping from a building when the water supply, gas and drainage lines have been disconnected in an approved manner under a permit.
- (7) Work involved in setting up for display of plumbing fixtures or appliances, when not connected to any supply or drainage lines, in a sales establishment.
- (8) Replacement of water conservation devices not requiring cutting into or removal of piping.
- (9) Work performed in buildings or structures owned and occupied by the State and Federal governments.

104.3 Replace this section as follows:

104.3 Application for Permit. Permit applicants shall file with the Department of Building Inspection an application on a form furnished for that purpose.

A permit for inspection of the proposed plumbing work set forth in the application will be issued to State-licensed contractors or to homeowners subject to the requirements of Section 104.1.1. A separate permit shall be obtained for each separate building, structure or property.

104.3.2 Replace this section as follows:

104.3.2 Inspections Not Covered by Permit Fees.

104.3.2.1 Off Hours of Inspection. Off-hour inspection may be performed outside normal inspection hours by prior arrangement and prepayment of fees as set forth in Section 110A, Table 1A-G - Inspections, Surveys and Reports - of the Building Code.

104.3.2.2 Reinspections. A reinspection fee shall be assessed for each inspection or reinspection made necessary by any of the following conditions:

- (1) When the portion of the work for which the inspection is requested is not complete or code complying.
- (2) When previously identified deficiencies in the work are not properly corrected.
- (3) When the approved construction documents are not available to the inspector.
- (4) When access is not provided on the date and time of the inspection appointment.
- (5) When work deviates from the approved construction documents.

The first reinspection for failure to comply with code requirements shall not be assessed a reinspection fee. All subsequent reinspections for the same or subsequent errors or omissions shall be charged a reinspection fee.

Subsequent to inspector determination of reinspection fee requirements, no required or requested inspections shall be made nor shall the job be given a certificate of final completion and occupancy or final approval until the required reinspection fees are paid. See Section 110A, Table 1A-G - Inspections, Surveys and Reports - of the Building Code for applicable fees.

104.3.2.3 Survey. A plumbing survey may be requested when a plumbing inspector's assistance is desired to establish code compliance of existing or proposed plumbing system requirements. See Section 110A, Table 1A-G - Inspections, Survey and Reports - of the Building Code for applicable fees.

104.4 Add a new second paragraph to this section as follows:

An issued permit entitles the permittee to proceed with the work described therein. The issuance of a permit does not constitute approval of any work done under that permit. Permits shall not be transferable.

104.4.3 Replace this section as follows:

104.4.3 Permit Expiration: Plumbing permits expire per Section 106A.4.4 of the San Francisco Building Code. Permit fees may be partially refunded if a written cancellation request is made to the Building Official prior to commencement of the permitted work and within 90 days of the date of permit issuance. See Section 110A, Table 1A-R - Refunds - of the Building Code for refunds.

104.4.3.1 Add the following section:

104.4.3.1 Commencement of Work on Permit Expired Due to Work Not Started. A new permit shall be obtained to undertake the work described on an expired permit on which no work was performed. If not more than one year has elapsed since the expiration of the original permit, the applicant is eligible for reduced fees. See Section 110A, Table 1A-B - Other Building Permit and Plan Review Fees - of the Building Code for applicable fees.

If a refund has been granted per Section 104.4.3, the applicant shall not be eligible for the reduced fees as set forth in Section 110A, Table 1A-B - Other Building Permit and Plan Review Fees - of the Building Code.

104.4.3.2 Add the following section:

104.4.3.2 Recommencement of Work on Permit Expired Due to Work Not Completed. The applicant shall obtain a new permit for the work not completed. The permit fee shall be based on work remaining to be done. Fees shall be as set forth in Section 110A, Table 1A-C - Plumbing/Mechanical Permit Issuance and Inspection Fees - of the Building Code.

104.5 Replace this section as follows:

104.5 Permit Fees. Before any permit is issued, the applicant shall pay to the Central Permit Bureau the fees as set forth in Section 110A, Table 1A-C - Plumbing/ Mechanical Permit Issuance and Inspection Fees -

of the Building Code. The replacement of a plumbing fixture or a gas appliance without a change in drainage, piping or venting shall not require the payment of permit issuance fee. A separate permit issuance fee shall be paid for each class of work, i.e., sewers and drainage, gas and water.

Final inspection will not be made unless all outstanding fees related to the permit work have been paid.

104.5.2 *Revise this section as follows:*

104.5.2 Investigation Fees. An investigation fee, in addition to the permit fee, shall be collected whether or not a permit is then or subsequently issued. See Section 110A, Table 1A-C - Plumbing/Mechanical Permit Issuance and Inspection Fees, and Table 1A-K - Penalties, Hearings, Code Enforcement Assessments - of the Building Code for applicable fees. The payment of such investigation fee shall not exempt a person from compliance with other provisions of this code, nor from a penalty prescribed by law.

The Director may reduce the investigation fee to two times the amount of the permit fee as called for in Section 110A, Table 1A-C - Plumbing/Mechanical Permit Issuance and Inspection Fees - of the Building Code for work that was constructed prior to the current building ownership or for work without permit which was done prior to January 1, 1967, if the owner files with the Director a notarized affidavit together with documents substantiating such dates of work.

Appeals of investigation fees may be filed with the Board of Appeals in the manner provided in Section 8 *et seq.* of the Business & Tax Regulations Code. Such filing shall be subject to the fees and rules of the Board of Appeals. The Board of Appeals, in reviewing the appeal, may reduce the appealed amount to not less than two times the permit fee as set forth in Section 110A, Table 1A-C - Plumbing/Mechanical Permit Issuance and Inspection Fees - of the Building Code.

104.5.3 *Replace this section as follows:*

104.5.3 Fee Refunds. For fee refunds, see Section 107A.6 of the Building Code.

SECTION 105.0 - INSPECTIONS AND TESTING

105.2.6 *Revise the fourth paragraph as follows:*

To obtain reinspection, the applicant shall file an application therefore in writing upon a form furnished for that purpose and pay the reinspection fee in accordance with Section 110A, Table 1A-G - Inspections, Surveys and Reports - of the Building Code.

SECTION 106.0 - VIOLATIONS AND PENALTIES

106.3 *Replace this section as follows:*

106.3 Penalties. Any person, the owner or the owner's authorized agent, who violates, disobeys, omits, neglects or refuses to comply with, or resists or opposes the execution of any of the provisions of this code, shall be liable for a civil penalty, not to exceed \$500 for each day such violation is committed or permitted to continue, which penalty shall be assessed and recovered in a civil action brought in the name of the people of the City and County of San Francisco by the City Attorney in any court of competent jurisdiction. Any penalty assessed and recovered in an action brought pursuant to this paragraph shall be paid to the City Treasurer and credited to the Department of Building Inspection's Special Fund.

Any person, the owner or the owner's authorized agent, who violates, disobeys, omits, neglects or refuses to comply with, or who resists or opposes the execution of any of the provisions of this code, shall be guilty of a misdemeanor, and upon conviction thereof shall be punished by a fine not exceeding \$500 or by imprisonment not exceeding six months, or by both such fine and imprisonment, unless otherwise provided in this code, and shall be deemed guilty of a separate offense for every day such violation, disobedience, omission, neglect or refusal shall continue. Any person who shall do any work in violation of any of the provisions of this code, and any person having charge of such work who shall permit it to be done, shall be

liable for the penalty provided.

It shall be unlawful for any person to interfere with the posting of any notice provided for in this code or to tear down or mutilate any such notice posted by the Department of Building Inspection.

106.5 Revise this section as follows:

106.5 Authority to Disconnect Utilities in Emergencies. The Authority Having Jurisdiction shall have the authority to disconnect a plumbing system to a building, structure or equipment regulated by this code in case of emergency where necessary to eliminate an immediate hazard to life or property. For notification procedures, see Section 102A.16 of the Building Code.

SECTION 107.0 – BOARD OF APPEALS

107.0 Replace this title and the entire section as follows:

109.0 107.0 Board of Examiners. Application may be made to the Board of Examiners for approval of alternate materials, methods and types of construction and for variances from the provisions of this code. See Building Code, Section 105A.1.

108.0 Add the following section:

SECTION 108.0 – ABATEMENT OF PUBLIC NUISANCE

108.0 Abatement of Public Nuisance. In order to abate a nuisance as defined in Section 216.0 of this code, the inspection and abatement procedures as set forth in Section 102A of the Building Code, including, but not limited to, Section 102A.3 through 102A.8, shall apply.

109.0 Add the following section:

SECTION 109.0 – REPAIRS TO DEFECTIVE BUILDING SEWERS

110.0 109.0 Repairs to Defective Building Sewers

110.1 109.1 General. Any defective building sewer found to be a nuisance or hazardous to the public shall be repaired at the owner's expense by a licensed plumbing contractor in accordance with this code. In the event the owner fails to repair the defective building sewer after written notice has been sent the owner by the Authority Having Jurisdiction, the Authority Having Jurisdiction shall abate the condition in accordance with Section 102A of the Building Code.

110.2 109.2 Cost of Repairs by City and County of San Francisco. Whenever the Authority Having Jurisdiction, pursuant to the authority conferred by this code and the Building Code, shall cause a building sewer to be repaired or replaced, the cost thereof shall be paid from the "Plumbing Building Sewer Revolving Fund" and assessed against the property served by said building sewer.

110.3 109.3 Plumbing Building Sewer Revolving Fund. A special revolving fund, to be known as the "Plumbing Building Sewer Revolving Fund," is hereby created for the purpose of defraying the costs and expenses which may be incurred by the Department of Building Inspection in carrying out the authority conferred by this code to repair or replace defective building sewers.

The Board of Supervisors shall transfer one-half of the funds appropriated to the "Side Sewer Repair" fund of the Department of Building Inspection or shall appropriate, establish or increase the special revolving fund with such funds as it may deem necessary in order to expedite performance of the work of repairing or replacing defective building sewers. The special revolving fund shall be replenished with all funds collected under the proceeding hereinafter provided for, either upon voluntary payments or as a result of the sale of the property after delinquency, or otherwise. Balances remaining in the Plumbing Building Sewer Revolving Fund at the close of any fiscal year shall be carried forward in such fund.

110.4 109.4 Assessment for Costs. The Authority Having Jurisdiction shall take action to have the costs of

all work done or caused to be done pursuant to this Section 109.0 assessed against the parcel or parcels of land upon which said building is served by the building sewer per Section 102A of the Building Code. Such costs shall include, in addition to all costs related to repairing or replacing the building sewer or demolishing and clearing the site, the City and County of San Francisco's costs in administering the required work. See Section 110A, Table 1A-K - Penalties, Hearings, Code Enforcement Assessments - of the Building Code for the applicable fee.

Chapter 2 DEFINITIONS

SECTION 201.0 – GENERAL

201.1 *Add the following to the end of the first sentence:*

Where words, terms and phrases are not defined, they shall have their ordinary accepted meaning within the context with which they are used.

SECTION 204.0 – B

204.0 *Add the following definition:*

Boiler. A closed vessel used for heating water or liquid, or for generating steam or vapor by direct application of heat from combustible fuels or electricity.

SECTION 208.0 – F

208.0 *Add the following definition:*

Foot Vent - See "Relief Vent," Section 220.0.

SECTION 216.0 – N

216.0 *Add the following items after Item (3) under definition of "Nuisance":*

- (4) Open, unsecured, leaking, plugged or otherwise defective sewer, gas or water lines.
- (5) Inadequate plumbing system maintenance, dilapidation, obsolescence, or damage.
- (6) Plumbing or plumbing fixtures, gas appliances or piping installed in violation of this code or without permit.
- (7) Where a change in occupancy classification is made without complying with the applicable provisions of this code and the Building Code.

SECTION 218.0 – P

218.0 *Revise this definition as follows:*

Plumbing System. Includes all potable water, alternate water sources, building supply, and distribution pipes; all plumbing fixtures and traps; all drainage and vent pipes; and all building drains and building sewers, including their respective joints and connections, devices, receptors, and appurtenances within the property lines of the premises and shall include potable water piping, potable water treating or using equipment, medical gas and medical vacuum systems, liquid and fuel gas piping, and water heaters and vents for same, and fire sprinkler systems. Plumbing systems shall include all plumbing appliances, plumbing appurtenances and plumbing fixtures.

SECTION 221.0 – S

221.0 Add the following definition:

Story. That portion of a building included between the upper surface of any floor and the upper surface of the floor next above. For the purposes of this code, balcony, loft and mezzanine levels that contain plumbing outlets are also to be considered as stories.

Chapter 3

GENERAL REGULATIONS

SECTION 313.0 – HANGERS AND SUPPORTS

313.8 313.9 Add the following section:

313.8 313.9 Materials.

313.8.1 313.9.1 Plumber's tape hanger iron may be used to secure pipe not greater than 2 inches (50.8 mm) in diameter.

313.8.2 313.9.2 Hanger iron shall be galvanized and not thinner than 22 gauge, 1/32-inch thick (0.8 mm) and 3/4-inch (19.05 mm) wide, securely nailed or screwed to the structure. When the strap-iron is formed around the pipe, it shall be secured with a 1/4-inch (6.35 mm) stove bolt.

Chapter 4

PLUMBING FIXTURES AND FIXTURE FITTINGS

SECTION 405 – PROHIBITED FIXTURES

405.0 Add the following section:

405.4 **Watercloset-Sink Combinations.** Watercloset-Sink combinations are not allowed in structures with treated alternate water piping.

SECTION 415.0 – DRINKING FOUNTAINS

415.2 Add the following section:

415.2.1 **Drink Tap Stations.** For new construction that provides one or more drinking fountains shall provide a Drink Tap Station per San Francisco Environment Code Section 2304.

Chapter 5

WATER HEATERS

SECTION 504.0 – WATER HEATER REQUIREMENTS

504.1 Add the following as the first paragraph of this section:

504.1 **Location.** Water Heaters mounted on the exterior of a building and located 7' or more above the floor or grade shall be provided with a permanent platform capable of supporting a tester or maintenance person.

Chapter 6

WATER SUPPLY AND DISTRIBUTION

SECTION 603.0 – CROSS-CONNECTION CONTROL

603.1 Add a third paragraph to this section as follows:

Structures with alternate water piping shall have a Reduced-Pressure Principle Backflow Prevention Assembly installed on the domestic supply as close as practical to the meter.

603.3 Add a second paragraph to this section as follows:

Refer to SFPUC's Rules & Regs Section "A and/or G Cross connection Control", Table 1 and Table 603.2 of the CPC. The more stringent shall apply.

603.5.6.4 Add the following section:

603.5.6.4 All such installations shall be approved in writing by the San Francisco Water Department prior to installation.

SECTION 604.0 – MATERIALS

604.1 Add the following sentence to the end of the second paragraph:

Connections between copper water piping and ferrous materials shall be made with dielectric or insulated fittings or brass nipples of 6 inches (152.4 mm) minimum length.

SECTION 606.0 – VALVES

606.2 Revise this section as follows:

606.2 Fullway Valve. A fullway valve controlling outlets shall be installed on the discharge side of each water meter and each unmetered water supply as near as possible to the point after where the water supply enters the building and before the first fitting or branch line. Water piping supplying more than one building on one premise shall be equipped with a separate fullway valve to each building, so arranged that the water supply can be turned on or off to any individual or separate building provided; however, that supply piping to a single-family residence and building accessory thereto shall be permitted to be controlled by one valve. Such shutoff valves shall be accessible. A fullway valve shall be installed on the discharge piping from water supply tanks at or near the tank. A fullway valve shall be installed on the cold water supply pipe to each water heater at or near the water heater. In cases where one water heater or boiler supplies hot water to multiple units additional fullway valves will be installed so that the hot water supplies to any apartment / unit / dwelling or condominium can be shut off without interrupting the hot water supply to any other apartment / unit / dwelling or condominium. These valves shall be accessible in the dwelling unit they control or other common area within the building.

606.3 Revise this section as follows:

606.3 Multidwelling Units. In multidwelling units, one or more shutoff valves shall be provided in each dwelling unit so that the hot and cold water supplies to any apartment / unit / dwelling or condominium can be shut off without interrupting the water supply to another apartment / unit / dwelling or condominium. These valves shall be accessible in the dwelling unit they control or other common area within the building.

606.3.1 Add the following section:

606.3.1 Any apartment / unit / dwelling or condominium where a remodel is performed shall meet the requirements of sections 606.2, 606.3 and 606.5.

606.5 Revise this section as follows:

606.5 Control Valve. A control valve shall be installed immediately ahead of each plumbing fixture hot

and cold water supply and water supplied appliances to permit servicing and replacement of individual fixtures.

606.9 Add the following section:

606.9 All buildings four stories or more in height or water supply greater than 40 feet above the water meter shall have an approved backflow assembly installed as near as possible to the water meter and before the first fitting or branch line. The backflow assembly installed shall be in accordance to the degree of hazard within the building, but in no case less than an approved double check assembly. See Table 603.2.

SECTION 609.0 – INSTALLATION, TESTING, UNIONS AND LOCATION

609.10.2 Add the following section:

609.10.2 Air Chambers. Air chambers shall be installed on all hot and cold water outlets supplying quick-acting valves to provide water hammer relief. The size of each air chamber shall be 24 times the diameter of the fixture supply.

609.10.3 Add the following section:

609.10.3 Quick-Acting Valves. The following valves shall be considered quick-acting: flushometers, single-handle faucets, single-handle tub and tub/shower combination control valves, single-handle shower control valves, rapid response electric solenoid valves (such as used on ice-makers, clothes washers, etc.) and any other appliance or fixture that dispenses water in a quick-open and close method in its operation.

Chapter 7 SANITARY DRAINAGE Part I – DRAINAGE SYSTEMS

SECTION 701.0 – GENERAL

701.2(2)(a) Revise this section as follows:

701.2(2)(a) ABS and PVC installations are limited to not more than two stories of areas of commercial or private residential accommodations.

701.2(3) Revise this section as follows:

701.2(3) No vitrified clay pipe or fittings shall be used aboveground or where pressurized by a pump or ejector or underground within the foundation line of the building. They shall be kept not less than 12 inches (305 mm) belowground.

701.2(7) Add the following section:

701.2(7) Copper tubing shall not be used for urinal drainage or applications which are detrimental to the integrity of copper tubing.

SECTION 706.0 – CHANGES IN DIRECTION OF DRAINAGE FLOW

706.4 Revise this section as follows:

706.4 Vertical to Horizontal. Vertical drainage lines connecting with horizontal drainage lines shall enter through 45 degree (0.79 rad) wye branches, combination wye and one-eighth bend branches, or other approved fittings of equivalent sweep. Branches or offsets of 60 degrees (1.05 rad) shall be permitted to be used where installed in a true vertical position. In buildings more than three stories in height, any fixture

within 10 feet (304 mm) of the connection of the vertical to horizontal change shall enter the horizontal drainage line at least 10 feet (304 mm) downstream from the change or may connect into the next vertical downstream line.

SECTION 710.0 – DRAINAGE OF FIXTURES LOCATED BELOW THE NEXT UPSTREAM MANHOLE OR BELOW THE MAIN SEWER LEVEL

710.1.1 Add the following section:

710.1.1 Drainage of Fixtures Located Below the Fresh Air Inlet. Where a fixture is installed with the flood rim level equal to or lower than the elevation of the fresh air inlet serving the house trap, the piping serving the fixture shall be protected by installing an approved type of backwater valve. Where a fixture is installed with the flood rim level higher than the elevation of the fresh air inlet serving the house trap, the fixture shall not discharge through such backwater valve.

Chapter 8 INDIRECT WASTES

No San Francisco Plumbing Code Amendments.

Chapter 9 VENTS

SECTION 901.0 – GENERAL

901.1 Add the following second paragraph to this section:

No mechanical device shall be installed in any venting system. Such venting system shall remain unobstructed to an approved termination.

SECTION 907.0 – VENT STACKS AND RELIEF VENTS

907.1 Revise the first sentence of this section as follows:

907.1 Drainage Stack. Each drainage stack that extends six (6) or more stories shall be served by a parallel vent stack, which shall extend undiminished in size from its upper terminal and connect to the drainage stack at or immediately below the lowest fixture drain.

907.3 Add the following section:

907.3 Vent Stacks and Relief Vents. Every building in which plumbing is installed shall have at least one main stack which shall run undiminished in size and as directly as possible from each building drain serving said building through to the open air above the roof.

For the purposes of this section, the main stack shall be defined as the largest size stack that is connected to a building drain or sewer.

A vent stack shall be installed with a soil or waste stack whenever relief vents or other branch vents are required in two or more branch intervals. A vent stack shall be installed in accordance with Section 706.1.

The size of the soil stack shall be determined by the total fixture units on that stack as per Table 703.2.

SECTION 911.0 – CIRCUIT VENTING

911.0 *Revise this section as follows:*

911.0 Circuit Venting. Circuit venting is not permitted unless it is approved as an alternative engineered design in accordance with Section 301.5 of this Code.

Chapter 10

TRAPS AND INTERCEPTORS

1001.3 *Add the following section:*

1001.3 Placement and Minimum Size of Building Traps. The building sewer or building drain shall have a building trap placed as near as possible to the curb line or immediately inside any subsidewalk basement wall under the sidewalk. Trap size shall be a minimum of 4 inches (101.6 mm).

SECTION 1008.0 – BUILDING TRAPS

1008.1 *Revise this section as follows:*

1008.1 General. Building traps shall not be installed except where required by the Authority Having Jurisdiction. Each building trap where installed shall be provided with a cleanout and with a relieving vent or fresh-air intake on the inlet side of the trap. Such trap shall have a fresh air inlet of not less than 4 inch (101.6 mm) diameter pipe. The inlet shall be covered by an approved perforated plate not less than 16 square inches (10,323 mm²). Perforations shall be not more than 3/8 inch (9.6 mm) diameter and provide an aggregate open area of not less than one-half the cross-sectional area of the sewer trap. The air inlet shall be connected to the building side of the trap and shall lead to the open air, terminating at a point not less than 10 feet (3.05 m) from any window or door.

SECTION 1016.0 – SAND INTERCEPTORS

1016.3 *Add the following section:*

1016.3.1 When drains are provided for planter boxes, such drains shall enter into the sanitary or storm drainage plumbing system by discharging into an approved sump, receiving tank or sand settling tank. No trap shall be installed between the planter box and any approved receptor. Sizes of drains shall conform to Table 703.2.

Catch basins or sumps to drain surface water or collect subsoil drainage shall meet the following requirements:

- (1) The catch basin or sump shall be poured in place, and all sides and bottom shall be watertight.
- (2) A removable metal grill approved for applied design loads shall be placed on top with a screen to prevent mosquito breeding.
- (3) Each catch basin shall be served with its own trap and cleanout, and shall connect to the storm or sanitary system independently.
- (4) If inlet is located below the building sewer or drain, a sump pump minimum of 1-1/2" (38.1 mm) outlet may be used. The bottom of sump shall maintain a 1'-0" (304.8 mm) distance from the inlet, creating a 1'-0" (304.8 mm) sand trap.
- (5) If the depth of the sump is over 5'-0" (1.52 m) a larger catch basin shall be required with a permanent ladder securely bolted to the interior to provide access for maintenance. A minimum clear space of 30" × 30"

(762 mm × 762 mm) shall be provided.

(6) A listed and approved plastic catch basin may be installed in areas of residential buildings that are not subjected to any vehicular traffic and shall be installed on a concrete base to prevent settling, provided all other code requirements of this section and the listing and installation requirements of such catch basin are met.

Chapter 11 STORM DRAINAGE

SECTION 1101.0 – GENERAL

1101.2.1 Add the following section:

1101.2.1 Leaders, Connection to Drain. All storm water or casual water from roof areas, balconies, lightwells, courtyards or similar areas which total more than 200 square feet (18.4 square meters) aggregate shall drain or be conveyed directly to the building drain, or building sewer, or to an approved alternate location based on approved geotechnical and engineering designs. Such drainage shall not be directed to flow onto adjacent property or over public way, including sidewalks. The opening of the leader shall meet the same requirements as Section 1103.0 of the California Plumbing Code.

1101.2.2 Add the following section:

1101.2.2 Temporary Provisions. When the stormwater sewer is not yet installed, the building stormwater drainage system may discharge into the sewer on the street side of the main trap as near to the curbline as possible.

1101.2.3 Add the following section:

1101.2.3 Temporary Provisions-Drain Trap. When, under the provisions of Section 1101.2.2 the building stormwater drainage system discharges to the sewer, a trap shall be placed in that drain at a point near where it branches into the sewer. The trap shall be supplied with clean water by an approved means such as a hose bibb or trap primer.

Chapter 12 FUEL GAS PIPING

SECTION 1208.0 – GAS PIPING SYSTEM DESIGN, MATERIALS, AND COMPONENTS

1208.5.1 Add a second paragraph as follows:

Gas piping in exterior locations, except as otherwise regulated by this code, shall be of galvanized iron or steel, with galvanized fittings.

Chapter 13 HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS

No San Francisco Plumbing Code Amendments.

Chapter 14

FIRESTOP PROTECTION

No San Francisco Plumbing Code Amendments.

Chapter 15

ALTERNATE WATER SOURCES FOR NONPOTABLE APPLICATIONS

No San Francisco Plumbing Code Amendments.

Chapter 16

NONPOTABLE RAINWATER CATCHMENT SYSTEMS

No San Francisco Plumbing Code Amendments.

Chapter 17

REFERENCED STANDARDS

No San Francisco Plumbing Code Amendments.

Appendix A

RECOMMENDED RULES FOR SIZING THE WATER SUPPLY SYSTEM

No San Francisco Plumbing Code Amendments.

Appendix B

EXPLANATORY NOTES ON COMBINATION WASTE AND VENT SYSTEMS

No San Francisco Plumbing Code Amendments.

Appendix D

SIZING STORMWATER DRAINAGE SYSTEMS

No San Francisco Plumbing Code Amendments.

Appendix H

PRIVATE SEWAGE DISPOSAL SYSTEMS

No San Francisco Plumbing Code Amendments.

Appendix I
INSTALLATION STANDARD FOR PEX TUBING
SYSTEMS FOR HOT- AND COLD-WATER
DISTRIBUTION

No San Francisco Plumbing Code Amendments.

Appendix J
COMBINATION OF INDOOR AND OUTDOOR
COMBUSTION AND VENTILATION OPENING DESIGN

No San Francisco Plumbing Code Amendments.

DRAFT

EXHIBIT A

STANDARD FINDINGS FOR SAN FRANCISCO BUILDING STANDARDS CODE AMENDMENTS

1. Certain buildings/occupancies in San Francisco are at increased risk for earthquake-induced failure and consequent fire due to local hazardous microzones, slide areas, and local liquefaction hazards. (Geology)
2. Certain buildings/occupancies in San Francisco are at increased risk of fire due to high density of buildings on very small lots, with many buildings built up to the property lines. (Topography)
3. Topography of San Francisco has led to development of a high density of buildings on small lots, necessitating special provisions for exiting, fire separation, or fire-resistive construction. (Topography)
4. Many buildings are built on steep hills and narrow streets, requiring special safety consideration. (Topography)
5. Additional fire, structural and other protection is required due to high building density and crowded occupancy. (Topography)
6. San Francisco has narrow, crowded sidewalks due to building and population density and unusual topography. (Topography)
7. All rain water in San Francisco drains to the building drains and sewer; unusual geology, occasional extremely high local rainfall amounts, and the configuration of the City as a peninsula restrict the installation of separate storm water and sewer systems. (Topography, Climate, Geology)
8. Moist, corrosive atmosphere of salt-laden fog in San Francisco necessitates additional requirements. (Climate)
9. Not a building standard; no local findings required.
10. Soil conditions in this region induce adverse reactions with some materials, leading to premature failures and subsequent unsanitary conditions. (Climate)
11. The region is subject to fluctuating rainfall due to changes in climatic conditions. (Climate)

12. San Francisco is a peninsula surrounded on three sides by water at sea level; mitigation of climate change impacts, including sea level rise, is critical to the long term protection of the local built environment and local infrastructure. (Topography)
13. Climate and potential climate change impacts San Francisco's water resources, including reservoirs and distribution facilities. (Climate)
14. Organic material in San Francisco's waste breaks down into methane gas which is a significant contributor to climate change. (Climate)
15. San Francisco is topographically constrained and its built environment occupies most available land, requiring minimization of debris and solid waste. (Topography)
16. Prevailing winds, coastal mountain ranges, and periodic seasonal high temperatures contribute to photochemical reactions that produce smog and ozone; limiting the emission of smog's chemical precursors - volatile organic chemicals and oxides of nitrogen - is necessary to health and safety. (Climate, Topography)
17. The aquifers underlying San Francisco are small relative to local population, necessitating ongoing water imports and special provisions to ensure efficient use of water in local buildings. (Geology)

2019 San Francisco Plumbing Code Findings

Section #	Finding #	Section #	Finding #
CHAPTER 1		104.4.3	9
101.1	9	104.4.3.1	9
103.1	9	104.4.3.2	9
103.4	9	104.5	9
103.5	9	104.5.2	9
103.6	9	104.5.3	9
103.7	9	105.2.6	9
104.1	9	106.3	9
104.1.1	9	106.5	9
104.1.2	9	107.0	9
104.2	9	108.0	9
104.3	9	109.0	9
104.3.2	9	109.1	9
104.3.2.1	9	109.2	9
104.3.2.2	9	109.3	9
104.3.2.3	9	109.4	9
104.4	9		

Section #	Finding #	Section #	Finding #
CHAPTER 2		CHAPTER 3	
201.1	9	313.9	1
204.0	9	313.9.1	1
208.0	9	313.9.2	1
216.0	9		
218.0	9		
221.0	9		
CHAPTER 4		CHAPTER 5	
405.4	7,10	504.1	4, 9
415.2.1	13		
CHAPTER 6		CHAPTER 7	
603.1	4	701.2(2)(a)	5,10
603.3	9	701.2(3)	1
603.5.6.4	9	701.2(7)	5
604.1	5	706.4	5,7
606.2	4	710.1.1	5,7
606.3	4		
606.3.1	4, 9	CHAPTER 8 No San Francisco Amendments	
606.5	4	CHAPTER 9	
606.9	5,7	901.1	5,7
609.10.2	4	907.1	2,4,14,16

609.10.3	4,9	907.3	2,4,14,16
----------	-----	-------	-----------

Section #	Finding #	Section #	Finding #
CHAPTER 10			
1001.3	3,7		
1008.1	4,7		
1016.3.1	4,7		
CHAPTER 11		CHAPTER 12	
1101.2.1	12,13,15	1208.5.1	16
1101.2.2	12,13,15	CHAPTER 13 No San Francisco Amendments	
1101.2.3	12,13,15	CHAPTER 14 No San Francisco Amendments	
CHAPTER 15 No San Francisco Amendments		CHAPTER 16 & 16A No San Francisco Amendments	
CHAPTER 17 No San Francisco Amendments		Appendix A, B, D, H, I, J No San Francisco Amendments	

n:\legana\as2019\1900415\01393209.doc



BUILDING INSPECTION COMMISSION (BIC) RECEIVED
 BOARD OF SUPERVISORS
 Department of Building Inspection Voice (415) 558-6164 Fax (415) 558-6509
 1660 Mission Street, San Francisco, California 94103-2414
 2019 SEP 23 AM 9:56
 BY *DW*

August 12, 2019

London N. Breed
 Mayor

COMMISSION

Angus McCarthy
 President

Debra Walker
 Vice-President

Kevin Clinch
 John Konstin
 Frank Lee
 Sam Moss
 James Warshell

Sonya Harris
 Secretary

Shirley Wong
 Assistant Secretary

Tom C. Hui
 S.E.
 C.B.O., Director

Ms. Angela Calvillo
 Clerk of the Board
 Board of Supervisors, City Hall
 1 Dr. Carlton B. Goodlett Place, Room 244
 San Francisco, CA 94102-4694

RE: Code amendments to the 2019 California Building Standards Code, including the Building, Existing Building, Residential, Mechanical, Plumbing, Electrical, and Green Building Codes and recommend approval to the Board of Supervisors.

Dear Ms. Calvillo:

On July 17, 2019 the Building Inspection Commission held a public hearing on the proposed Code amendments referenced above.

The Commission voted unanimously (6-0) to recommend that the Board of Supervisors approve the amendments.

The Commissioners voted as follows:

President McCarthy	Yes	Vice-President Walker	Yes
Commissioner Clinch	Yes	Commissioner Konstin	Excused
Commissioner Lee	Yes	Commissioner Moss	Yes
Commissioner Warshell	Yes		

Enclosed please find the Code Advisory Committee's recommendation to the BIC. Under separate cover, copies of the proposed amendments will follow from the Technical Services Division of the Department of Building Inspection.

Should you have any questions, please do not hesitate to call me at 558-6164.

Sincerely,

Sonya Harris

Sonya Harris
 Commission Secretary

cc: Tom C. Hui, S.E., C.B.O., Director
Mayor London N. Breed
Supervisor Vallie Brown
Supervisor Sandra Lee Fewer
Supervisor Matt Haney
Supervisor Rafael Mandelman
Supervisor Gordon Mar
Supervisor Aaron Peskin
Supervisor Hillary Ronen
Supervisor Ahsha Safai
Supervisor Catherine Stefani
Supervisor Shamann Walton
Supervisor Norman Yee
Deputy City Attorney Robb Kapla

805-11
000-110-11
1-800-110-11
Mayor's Office
Dep. City Atty

RECEIVED
BOARD OF SUPERVISORS
SAN FRANCISCO

City Hall
2019 OCT 02 B. Adolph Place, Room 244
San Francisco, CA 94102-4689

By *JR*
Tel. No. 554-6516
Fax No. 554-7674
TDD/TTY No. 544-6546



President, District 7
BOARD of SUPERVISORS

Norman Yee

PRESIDENTIAL ACTION

Date: October 1, 2019
To: Angela Calvillo, Clerk of the Board of Supervisors

Madam Clerk,
Pursuant to Board Rules, I am hereby:

Waiving 30-Day Rule. (Board Rule No. 3.23)

File No. 190963 Department
(Primary Sponsor)

Title: Plumbing Code - Repeal of Existing 2016 Code and Enactment of 2019 Edition

Transferring (Board Rule No 3.3)

File No. (Primary Sponsor)

Title:

From: Committee

To: Committee

Assigning Temporary Committee Appointment (Board Rule No: 3.1)

Supervisor: Replacing Supervisor:

For: Meeting
(Date) (Committee)

Duration: Partial Full Meeting

Start Time End Time

Until original Committee Member returns

Norman Yee
Norman Yee, President
Board of Supervisors

The following person may be contacted regarding this matter:



Michelle Yu, Manager
Technical Services Division
Department of Building Inspection
Phone: (415) 558-6059

Attachments: As stated

Table of Content

1. General
 - a. Approval letter from the Building Inspection Commission
2. Building Code and Residential Building Requirements
 - a. Legislative Digest
 - b. San Francisco Building Code Ordinance including Residential Building Requirements
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Building Code Amendments
 - f. Residential Building Requirements – See Chapter 36 of the San Francisco Building Code
3. Existing Building Code
 - a. Legislative Digest
 - b. San Francisco Existing Building Code Ordinance
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Existing Building Code Amendments
4. Electrical Code
 - a. Legislative Digest
 - b. San Francisco Electrical Code Ordinance
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Electrical Code Amendments
5. Mechanical Code
 - a. Legislative Digest
 - b. San Francisco Mechanical Code Ordinance
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Mechanical Code Amendments
6. Plumbing Code
 - a. Legislative Digest
 - b. San Francisco Plumbing Code Ordinance
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Plumbing Code Amendments
7. Green Building Code
 - a. Legislative Digest
 - b. San Francisco Green Building Code Ordinance
 - c. Exhibit A – Standard Findings
 - d. Findings
 - e. San Francisco Green Building Code Amendments
 - f. Nonresidential New Construction Reach Code Cost Effectiveness Study
 - g. Cost-effectiveness Study: Low-Rise Residential New Construction