

Re: Referral: File No. 101053 (Consistent Street Frontage Controls) [Notes Link](#)

Barbara Schultheis to Alisa Somera
:

03/09/2011 02:19 PM

Alisa-

I have a concern about Section 136 of the ordinance regarding obstructions over streets and alleys. My concern is for narrow streets or alleys that do not have sidewalks. The language appears to allow certain obstructions to project into the street or alley to be as low as 7 ft.. This could conflict with the SF Fire Code if the street or alley provided clearance width of 20 ft. or less. The Fire Code specifies that buildings are required to have fire dept access roads with a minimum width of 20 ft and a vertical clearance of 13 ft. 6 inches.

Barbara Schultheis
Fire Marshal
San Francisco Fire Department
698 2nd St.
San Francisco, CA 94107
(415) 558-3320 ph.
(415) 558-3322 fax