

1 [Ordinance amending San Francisco Fire Code to require self-contained breathing
2 replenishment systems in high rise buildings.]

3 **Ordinance amending San Francisco Fire Code by adding Section 9001.1.4 to require**
4 **self-contained breathing replenishment systems in high rise buildings where permits**
5 **have been issued after June 30, 2004.**

6 Note: Additions are single-underline italics Times New Roman;
7 deletions are ~~strikethrough italics Times New Roman~~.
8 Board amendment additions are double underlined.
9 Board amendment deletions are ~~strikethrough normal~~.

10 Be it ordained by the People of the City and County of San Francisco:

11 Section 1. The San Francisco Fire Code is hereby amended by amending Section
12 9001.1.4, to read as follows:

13 Sec. 1. The San Francisco Fire Code is hereby amended by adding Section 9001.1.4
14 Section 9001.1.4. Local Standards for High Rise Buildings and Tunnels.

15 A self-contained breathing air replenishment system shall be installed in all buildings
16 having floors used for human occupancy located more than 75 feet (22 860 mm) above the
17 lowest level of fire department vehicle access. This requirement shall apply for all buildings
18 meeting this definition when the building permit application for construction was made after
19 March 30, 2004.

20 A self-contained breathing air replenishment system will provide a supply of
21 pressurized breathing air through a permanently installed piping distribution system for the
22 replenishment of portable breathing air equipment.

23 The self-contained breathing air replenishment system shall be installed in all new
24 underground transportation or pedestrian tunnels exceeding 300 feet (91 440 mm).

1 The self-contained breathing air replenishment system shall meet the specifications set
2 forth in Appendix VI-J, Section 7.08 Self-Contained Breathing Air Replenishment System.

3
4
5 APPROVED AS TO FORM:
6 DENNIS J. HERRERA, City Attorney

7 By: _____
8 Margaret W. Baumgartner
9 Deputy City Attorney

10
11
12
13
14
15
16
17
18
19
20
21
22
23 Supervisors Bevan Dufty, Chris Daly