1	[Ordinance amending San Francisco Fire Code to require self-contained breathing replenishment systems in high rise buildings.]
2	
3	Ordinance amending San Francisco Fire Code by adding Section 9001.1.4 to require
4	self-contained breathing replenishment systems in high rise buildings where permits
5	have been issued after June 30, 200 4 <u>March 30, 2004</u> .
6 7 8	Note: Additions are <u>single-underline italics Times New Roman</u> ; deletions are strikethrough italics Times New Roman . Board amendment additions are <u>double underlined</u> . Board amendment deletions are strikethrough normal .
9	Be it ordained by the People of the City and County of San Francisco:
10	Section 1. The San Francisco Fire Code is hereby amended by amending Section
11 12	9001.1.4, to read as follows:
12 13	Sec. 1. The San Francisco Fire Code is hereby amended by adding Section 9001.1.4
13	Section 9001.1.4. Local Standards for High Rise Buildings and Tunnels.
15	A self-contained breathing air replenishment system shall be installed in all buildings
16	having floors used for human occupancy located more than 75 feet (22 860 mm) above the
17	lowest level of fire department vehicle access. This requirement shall apply for all buildings
18	meeting this definition when the building permit application for construction was made after
19	March 30, 2004.
20	A self-contained breathing air replenishment system will provide a supply of
21	pressurized breathing air through a permanently installed piping distribution system for the
22	replenishment of portable breathing air equipment.
23	The self-contained breathing air replenishment system shall be installed in all new
24	underground transportation or pedestrian tunnels exceeding 300 feet (91 440 mm).
25	

1	The self-contained breathing air replenishment system shall meet the specifications set
2	forth in Appendix VI-J, Section 7.08 Self-Contained Breathing Air Replenishment System.
3	
4	APPROVED AS TO FORM:
5	DENNIS J. HERRERA, City Attorney
6	By:
7	Margaret W. Baumgartner Deputy City Attorney
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19 20	
20 21	
22	
22	Supervisors Bevan Dufty, Chris Daly
23	
25	
_•	