


Non-potable Water Ordinance Updates

Board of Supervisors Public Safety and Neighborhood Services Committee

John Scarpulla September 9, 2021



Non-potable Water Ordinance



- Applies to new buildings and development projects 250,000 gross square feet or greater
- Required to treat and reuse graywater, rainwater, and foundation drainage to meet toilet flushing and irrigation demands onsite
- Applicable city-wide



Non-potable Ordinance Requires City Family Coordination

SFPUC	SFDPH-EH	SFDBI	SFPW
Program Administration and Cross-Connection Control	Environmental Health	Construction	Right of Way and Mapping
Review onsite non- potable water supplies &	Issue water quality & monitoring requirements Review and approve nonpotable engineering report Issue permit to operate onsite systems Review water quality reporting	Conduct Plumbing Plan check and issue Plumbing Permit Inspect and approve system installations	Issue Encroachment Permits as needed for infrastructure in the Right-of-Way (if needed) Includes condition on a subdivision map or a parcel map requiring compliance with the Non- potable Ordinance prior to approval and issuance of said map (if applicable)

Source: San Francisco Public Utilities Commission




San Francisco's Evolving Onsite Water Reuse Program

2012 2013 2015 2019

Single District-Building Scale District- Scale District- 250,000 gsf District- 250,000 g



Examples of Mandatory NPO Projects



Mission Rock

Chase Center

Fifteen Fifty Mission



Proposed NPO Amendments



- Opportunity to further increase potable water offsets from new buildings and development projects
- Analysis of NPO program resulting in streamlined ordinance requirements
- Increased opportunities for costeffective systems



Proposed NPO Amendments



- Lower square footage threshold to any building(s) over 100,000 gross square feet
- Buildings that are 100% commercial to reuse all wastewater, not just graywater, onsite
- Multi-family residential and mixed-use residential buildings to meet clothes washing demands in addition to toilet flushing and irrigation demand



Additional Proposed NPO Amendments

Exempt:

- 100% affordable housing and homeless supportive housing
- Hospital, health service, and institutional health care facilities
- Facilities zoned for Production, Distribution, Repair (PDR) and industrial use
- Require A/C condensate to be reused
- Require projects to reuse water onsite for drain trap priming
- Collection and reuse of rainwater will be allowed not required
- Modify SFDPH penalty structure to improve enforcement and increase SFDPH application fee to cover oversight



Proposed NPO Amendments



- Opportunity to further increase potable water offsets from new buildings and development projects
- By 2040, mandatory NPO projects can achieve water savings equivalent to 26,200 SF residents daily water use
- Amendments can achieve additional water savings equivalent to 5,500 SF residents daily water use



Thank you